

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

Georg Fischer Piping Systems AG

Ebnatstrasse 111, 8201 Schaffhausen, Switzerland

the Certificate No: **Z02085** for the PROFIBUS device:

Model Name: EA25-250
 Revision: 1.00; SW/FW: V1.00; HW: Rev. C
 GSD: GFPS0FC6.GSD, File Version: 20.09.2016

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/> DP-V0	MS0, Sync, Freeze, Fail_Safe, Set_Slave_Add
<input checked="" type="checkbox"/> Physical Layer	RS485

Test Report Number: 637-1
 Authorized Test Laboratory: SIEMENS AG, Fürth, Germany

The tests were executed in accordance with the following documents:
 "Test Specifications for PROFIBUS DP Slaves, Version 3.09, September 2008".

This certificate is granted according to the document:
 "Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by October 06, 2019 the certificate is valid for life.

Karlsruhe, September 27, 2016


Board of PROFIBUS Nutzerorganisation e. V.



(Official in Charge)



(Karsten Schneider)



(K.-P. Lindner)